

Energy performance certificate (EPC)

13 Wellington Street LUTON LU1 2QH	Energy rating B	Valid until: 3 March 2036
		Certificate number: 0075-1208-9306-8714-1504

Property type

Restaurants and Cafes/Drinking
Establishments/Takeaways

Total floor area


83 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built



If typical of the existing stock



Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	70.25
Primary energy use (kWh/m2 per year)	505

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/2180-4517-9060-5104-7805\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Anees Farooq
Telephone	07898232710
Email	aneesfarooq87@gmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID210148
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Employer	EPC SPECIALIST
Employer address	5 CULVERHOUSE ROAD
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	3 March 2026
Date of certificate	4 March 2026